

From: [Craig Samek](#)
To: [Marshall, Paul](#)
Cc: [Justin Vondrak](#); [Mark Simms](#); ["Kim Cole"](#)
Subject: Sioux City, IA IPP Industry SNC Determination
Date: Wednesday, February 13, 2019 1:06:39 PM

Good afternoon, Mr. Marshall.

I, on behalf of the Sioux City IPP, would appreciate if you could give guidance and clarification as to SNC determination for Big Ox Energy for the second half of 2018. They were already published for SNC for discharges and interference for the first half of the year. However, there were no effluent violations that were attributable to BOE discharges and did not meet TRC or Chronic Violation criteria for TSS discharge limits. They did however, discharge TSS levels that caused us to exceed our MAHL Monthly Average TSS lbs./day in July and contributed to process inhibitions and slowing necessary repairs to primary clarifiers.

We feel that this constitutes SNC but would like your input.

Let me know if you have questions, and thank you for your assistance.

Sincerely,

Craig Samek
SC WWTP
Pretreatment Coordinator

712-279-6987
3100 S Lewis Blvd
Sioux City, IA 51106
csamek@sioux-city.org